



C-900 Pipe Size	Outside Diameter (OD)	Bell Length (Inches)	Reference Mark (Inches)	DR 25 (PC 165) Min. Walls	DR 18* (PC 235) Min. Walls	DR 14** (PC 310) Min. Walls	DR 25*** Approximate Bell Diameter (Inches)	DR 18*** Approximate Bell Diameter (Inches)	DR 14*** Approximate Bell Diameter (Inches)
4"	4.800	5	4.5	0.192	0.267	0.343	5.46	5.77	6.06
6"	6.900	6.5	5.5	0.276	0.383	0.493	7.91	8.33	8.76
8"	9.050	7.5	6.5	0.362	0.503	0.646	10.40	10.95	11.52
10"	11.100	9	8	0.444	0.617	0.793	12.77	13.45	14.17
12"	13.200	9.5	8.75	0.528	0.733	0.943	15.19	16.02	16.85

Bell lengths and reference marks may vary up to +/- 1/2"

- \* The DR18 line of pipe is Pressure Class 150 per Factory Mutual (FM) Standards
- \*\* The DR14 line of pipe is Pressure Class 200 per Factory Mutual (FM) Standards
- \*\*\* Bell diameters may vary due to the fluctuation of the walls

